



1. SUBSTRATE
2. DECK SUPPORTED VENT STACK (PRIME BEFORE APPLYING SPI)
3. TECH GUARD COATING SYSTEM
4. SPRAYED POLYURETHANE INSULATION (TECH GUARD)

NOTE:  
 VENT STACKS AND OTHER PIPES SHOULD HAVE A MINIMUM OF 12 INCHES (305mm) OF CLEARANCE ON ALL SIDES FROM WALLS, CURBS, AND OTHER PROJECTIONS TO FACILITATE PROPER FLASHING

  	PLUMBING VENT (dwg. 43)		DRAWN BY:	DATE:	APPROVED:
	3003 North 73rd Street, Scottsdale, AZ 85251 402 East Grand Road, Tucson, AZ 85705		SCALE:	PROJECT NO:	DRAWING NO.