



1. SUBSTRATE
2. FULL PLATFORM MIN. 2 x 8 CONSTRUCTION
3. ANGLE BRACKET-PLATFORM TO ROOF
4. SPRAYED POLYURETHANE INSULATION (TECH GUARD)
5. TECH GUARD COATING SYSTEM
6. MINIMUM 1/2" PLYWOOD PLATFORM TOP
7. HENRY RUFTAC OR SINGLE PLY MEMBRANE
8. 24 GA. GALVANIZED SEAMLESS OR STANDING SEAM PLATFORM COVER

  	HVAC/EQUIPMENT PLATFORM (dwg. 53)		DRAWN BY:	DATE:	APPROVED:
	3003 North 73rd Street, Scottsdale, AZ 85251 402 East Grand Road, Tuscon, AZ 85705		SCALE:	PROJECT NO:	DRAWING NO.