



1. SUBSTRATE
2. DECK SUPPORTED VENT STACK (PRIME BEFORE APPLYING SPI)
3. TECH GUARD COATING SYSTEM
4. SPRAYED POLYURETHANE INSULATION (TECH GUARD)

NOTE:
 VENT STACKS AND OTHER PIPES SHOULD HAVE A MINIMUM OF 12" (305MM)
 CLEARANCE ON ALL SIDES FROM WALLS, CURBS, AND OTHER PROJECTIONS TO FACILITATE
 PROPER FLASHING



PLUMBING VENT (dwg. 43)

3003 NORTH 73RD STREET, SCOTTSDALE, AZ 85251
 402 EAST GRAND ROAD, TUCSON, AZ 85705

DRAWN BY:

DRAWN BY:

APPROVED:

SCALE:

PROJECT NO:

DRAWING NO: